

# Bid Data Sheet

ITB Clause	
1.1	<p>The PROCURING ENTITY is <b>Tubod-Baroy Water District</b>.</p> <p>The name of the Contract is <b>Supply, Delivery, Installation and Commissioning of Fully Automatic Advanced Catalytic Media Multi Layer Filter System</b>.</p> <p>The identification number of the Contract is <b>2022-02-019</b>.</p>
2	<p>The Funding Source is:</p> <p>The Government of the Philippines (GOP) through <b>Corporate Operating Budget</b> in the amount of <b>Seven Million Two Hundred Thousand Pesos (₱7,200,000.00) Monthly installment payable within 3 years after commissioning</b>.</p> <p>The name of the Project is <b>Supply, Delivery, Installation and Commissioning of Fully Automatic Advanced Catalytic Media Multi Layer Filter System</b></p>
5.1	No further instructions.
5.2	Bidding is restricted to eligible bidders as defined in ITB Clause 5.1.
5.4	No further instructions.
5.5	No further instructions.
6.3	No further instructions.
7	No further instructions.
8.1	Subcontracting is not allowed.
8.2	Not applicable.
9.1	The Procuring Entity will hold a pre-bid conference for this Project on <b><u>10:30 AM March 2, 2022</u></b> at <b>Tubod-Baroy Water District Office, Sagadan, Tubod, Lanao del Norte</b>
10.1	<p>The Procuring Entity's address is:</p> <p>Provincial Trade Center, Sagadan, Poblacion, Tubod Lano del Norte</p> <p>BAC Secretariat</p>

	(063) 227 6294 ; 09164458219  tbwd07@yahoo.com
12.1	The first envelope shall contain the eligibility and technical documents stated in the <b>ITB</b> Clause. However, if the Bidder maintains a current and updated file of its Class “A” Documents with the Procuring Entity, a certification to that effect issued by its BAC may be submitted in lieu of the Class “A” Documents.
12.1(a)(i)	No other acceptable proof of registration is recognized.”
12.1(a)(iii)	No further instructions.
12.1(a)(iv)	No further instructions.
13.1	No additional Requirements”
13.2	The ABC is <b>Seven Million Two Hundred Thousand Pesos (₱7,200,000.00)</b> within 3 years after commissioning (monthly installment). Any bid with a financial component exceeding this amount shall not be accepted.
14.2	No further instructions.”
15.4	Bid Prices shall be fixed. Adjustable price proposals shall be treated as non-responsive and shall be rejected.  Price escalation may be allowed in extraordinary circumstances as may be determined by the National Economic and Development Authority in accordance with the Civil Code of the Philippines, and upon the recommendation of the Procuring Entity.
16.1	The bid prices shall be quoted in Philippine Pesos.
16.3	No further instructions.
17.1	Bids will be valid until April 23, 2022.
18.1	The bid security shall be in the following amount:  <ol style="list-style-type: none"> <li>1. One Hundred Forty Four Thousand (₱144,000.00), if bid security is in cash, cashier’s/manager’s check, bank draft/guarantee or irrevocable letter of credit;</li> <li>2. Three Hundred Sixty Thousand Pesos (₱360,000.00) if bid security is in Surety Bond; or</li> <li>3. Any combination of the foregoing proportionate to the share of form with respect to total amount of security.</li> </ol>

18.2	The bid security shall be valid until 120 calendar days from the date of opening of bid.
18.5(a)(iv)	<ol style="list-style-type: none"> <li>1. Submission of eligibility requirements containing false information or falsified documents.</li> <li>2. Submission of bids that contain false information or falsified documents, or the concealment of such information in the bids in order to influence the outcome of eligibility screening or any other stage of the public bidding.</li> <li>3. Allowing the use of one's name, or using the name of another for purposes of public bidding.</li> <li>4. Withdrawal of a bid, or refusal to accept an award, or enter into contract with the Government without justifiable cause, after the Bidder had been adjudged as having submitted the Lowest Calculated and Responsive Bid.</li> <li>5. Refusal or failure to post the required performance security within the prescribed time.</li> <li>6. Refusal to clarify or validate in writing its bid during post-qualification within a period of seven (7) calendar days from receipt of the request for clarification.</li> <li>7. Any documented unsolicited attempt by a bidder to unduly influence the outcome of the bidding in his favor.</li> <li>8. Failure of the potential joint venture partners to enter into the joint venture after the bid is declared as successful.</li> <li>9. All other acts that tend to defeat the purpose of the competitive bidding, such as habitually withdrawing from bidding, submitting late Bids or patently insufficient bid, for at least three (3) times within a year, except for valid reasons.</li> </ol>
18.5(b)(iii)	No further instructions.
20.1	No further instructions.
20.3	Each Bidder shall submit one (1) original and two (2) copies of the first and second components of its bid.
21	<p>The address for submission of bids is TBWD Office, Provincial Trade Center, Sagadan, Poblacion, Tubod Lanao del Norte.</p> <p>The deadline for submission of bids is March 14, 2022 at 10:30 in the morning.</p>
24.1	The place of bid opening is TBWD Office, Provincial Trade Center,

	Sagadan, Poblacion, Tubod Lanao del Norte. The date and time of bid opening is March 14, 2022 at 10:30 in the morning.															
25.1	No further instructions.															
27.3	No further instructions.															
27.3(b)	Bid modification is not allowed															
27.5	No further instructions.															
28.2(b)	Bidders have option to submit manually filed tax returns or tax returns filed through the Electronic Filing and Payments System (EFPS).  NOTE: The latest income and business tax returns are those within the last six months preceding the date of bid submission.															
31.4(g)	<p>Catalytic Media Filtration System for Turbidity, Iron and Manganese.</p> <p>Filtration Flow Rate : 2,070 cbm / day @ 23.0 hours operation  Feed Flow Rate : 25 liters per second (average)  Backwash Flow Rate : 30 cbm/ hr  Recovery Rate : 98% depending of water quality  Operating Pressure : 5-30 psi  Vessel : 1220mm x 1830mm  Make : Fiber Reinforced Plastic (FRP)  Opt. Pressure : Up to 100 psi  Temperature : 5-50 Celcius  Piping : Polyvinyl Chloride Pipes and Black Iron Pipes</p> <table border="0"> <thead> <tr> <th><b>Parameters</b></th> <th><b>Feed</b></th> <th><b>Product Water</b></th> </tr> </thead> <tbody> <tr> <td>Total Suspended Solids (TSS)</td> <td>: &lt; 30 mg/l</td> <td>&lt; 5mg/l</td> </tr> <tr> <td>Turbidity</td> <td>: &lt; 15 NTU</td> <td>&lt; 5 NTU</td> </tr> <tr> <td>Iron</td> <td>: up to 10 mg/l</td> <td>&lt; 0.05 mg/l</td> </tr> <tr> <td>Manganese</td> <td>: up to 2 mg/l</td> <td>&lt; 0.01 mg/l</td> </tr> </tbody> </table>	<b>Parameters</b>	<b>Feed</b>	<b>Product Water</b>	Total Suspended Solids (TSS)	: < 30 mg/l	< 5mg/l	Turbidity	: < 15 NTU	< 5 NTU	Iron	: up to 10 mg/l	< 0.05 mg/l	Manganese	: up to 2 mg/l	< 0.01 mg/l
<b>Parameters</b>	<b>Feed</b>	<b>Product Water</b>														
Total Suspended Solids (TSS)	: < 30 mg/l	< 5mg/l														
Turbidity	: < 15 NTU	< 5 NTU														
Iron	: up to 10 mg/l	< 0.05 mg/l														
Manganese	: up to 2 mg/l	< 0.01 mg/l														
33.2	The effective date of the Contract is upon approval of Notice to Proceed.															

